

**SEW INFRASTRUCTURES LIMITED queries request dated 01.11.2017**

**LIST OF QUERIES FOR PRE-BID MEETING FOR HIRAKUD SPILLWAY PROJECT**

SL No	Doc	Clause	Page No.	Queries	Clarification
1	P.Q. Criteria				
a)		E.3.Q.3.1		As per the Document the bidder shall demonstrate that it has access or has available liquid assets For Rs. 76 Crore for the subject contract and it is specified that each member shall meet the requirement. It is requested that this shall be met by all partners of joint venture combined in 100% irrespective of their J/V share.	The provision of this clause stands.
b)		Q.4.2(a)(ii)		It is requested to be clarified that the specialised for making construction drawings need not be a J/V partner.	JV is not mandatory
c)		Q.4.2(a)(iii)		It is also requested to be consider that an affidavit by the lead partner for employing a specialist firm shall be sufficient at the stage, and after award of works, the specialist firm can be employed with approval of the Department.	The provision of this clause stands.
d)		Q.4.2(b)(idii)		As per the Document the bidder shall have the specific construction experience of fabrication and erection of Gantry crane of 50 M.T. Capacity. As per the BOQ the capacity of Crane required is only 50 M.T. It is request that the shall be reduced to the 40 M.T. (Similar to other items of the work like concrete).	The provision of this clause stands.
2	General			Period of execution is given as 30 months. It is requested tht thi shall be increased to 48 month by considering moonson and time of making drawings approval etc.	The provision of this clause stands.
3	Procurement of sand			About 2.50 Lakhs cubic meter of sand is needed for the work and the sand is a natural resources and shall be preserved under environment aspect. It is requested to consider manufactured sand.	Agreed. However the manufactured sand is required to comply with its technical specifications.
4	Suitable material from excavation site shall used in work.			It is requested to consider re-use of excavated materials like stone, gravels etc. if suitable for use on the work.	Suitable material from excavation site complying with technical specification can be used .
5	Recoveries for non employment of staff.			The Recoveries proposed in the documents are very very high. It is requested to reduce the same.	The provision of this clause stands.
6				It is requested to reduce the performance warranty to 5% of the Contract value as the practice in other tenders of other states.	The provision of this clause stands.
7				It is requested that the retention money recovered from the bills shall be released against the submission of BGs	The provision of this clause stands.
8				It is requested that the GST shall be kept under the scope of the Department because of no clarity on exemption etc.	All quoted rates should be inclusive of all taxes, duties,fee,GST as per prevailing norms of Govt. of Odisha and Govt. of India
9				It is requested tht the date of submission of tenders be extended by about 6 weeks for making a detailed analysis and making an competitive bid.	No Extension,the existing provision stands.